

**Marlboro Township
Department of Administration
1979 Township Drive
Marlboro, NJ 07746**

RESPONSE TO REQUEST FOR CLARIFICATION

**CLARIFICATION NO. 1
Date: Friday, June 21, 2024**

Questions have been raised by prospective bidders with respect to the

**PROVISION OF LEAK DETECTION SURVEYS FOR THE TOWNSHIP OF MARLBORO
DEPARTMENT OF PUBLIC WORKS (DPW) WATER UTILITY DIVISION
(Bid 2024-15)**

Please be advised as follows:

Q1 : Could the Town provide a pipe inventory of total lengths by size and materials?

A: Please see the pipe material inventory list.

Material	Feet
Asbestos Cement	245,363
Cast Iron	1,930
Concrete Steel Cylinder	0
Ductile Iron	586,241
High Density Polyethylene	1,123
Polyvinyl Chloride	6,319

Q2 : Do the maps that the Town supplies indicate the pipe materials and size ?

A: Yes. Please see the page T-1, section 11010-4 General

The Township's Water System GIS Mapping will be made available to the successful bidder. Access to the GIS Mapping will be limited to viewing the Contractor's use while planning, identifying water main locations and performing the leak detection survey

Please be reminded that bids will be received and opened at 10:00 AM on Wednesday, July 24, 2024.

