

**Marlboro Township
Department of Administration
1979 Township Drive
Marlboro, NJ 07746**

RESPONSE TO REQUEST FOR CLARIFICATION

**CLARIFICATION NO. 2
Date: Wednesday, July 17, 2024**

Questions have been raised by prospective bidders with respect to the

**PROVISION OF 2024 WATER DISTRIBUTION SYSTEM “BLOSSOM HEIGHTS/GEORGETOWN
MANOR, CONOVER HILLS, HIGHLAND CREST/JUNCTION TRAIL, MARLBORO GARDENS AND
WINDING BROOK/SHALLOW BROOK.” - PREVENTATIVE VALVE MAINTENANCE PROGRAM
(Bid 2024-17)**

Please be advised as follows:

Q 1: “Do we need to keep the system pressurized while replacing the valve bonnet & other parts? Is it possible to isolate the valves which will be worked on?”

A: Please See page T-6, Scope of Work, Unidentified Issue (S), item a

The water system shall remain pressurized during all preventative valve maintenance work. Should any water mains need to be shut-down to complete the work do to unforeseen circumstances, the contractor is required to coordinate the required shutdown with the MTWUD Engineering Project Manager.

Please be reminded that bids will be received and opened at 10:00 AM on Wednesday, July 31, 2024.